



1 **EC TYPE-EXAMINATION CERTIFICATE**

2 Component intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 Certificate Number: **Sira 99ATEX1121U** Issue: **11**

4 Component: **IR1xxxxxx-Series Gas Sensing Head**

5 Applicant: **SGX Sensortech (IS) Ltd**

6 Address: **2 Hanbury Road
Widford Industrial Estate
Chelmsford
Essex CM1 3AE
UK**

7 This component and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

8 Sira Certification Service, notified body number 0518 in accordance with Article 9 of Directive 94/9/EC of 23 March 1994, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of a component intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2006

EN 60079-1:2007

10 The sign 'U' is placed after the certificate number to indicate that the product assessed is a component and may be subject to further assessment when incorporated into equipment. Any special conditions for safe use are listed in the schedule to this certificate.

11 This EC type-examination certificate relates only to the design and construction of the specified component. If applicable, further requirements of this Directive apply to the manufacture and supply of this component.

12 The marking of the component shall include the following:

IR1nGJS Series



II 2G
Ex d IIC Gb
T_a -40°C to +75°C

All other Series



II 2G
Ex d IIC Gb
T_a -20°C to +55°C

Project Number 30229

C Ellaby
Deputy Certification Manager

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

Form 9401 Issue 1

Page 1 of 5



SCHEDULE

EC TYPE-EXAMINATION CERTIFICATE

Sira 99ATEX1121U
Issue 11

13 DESCRIPTION OF COMPONENT

The IR1xxxxxx-series Gas Sensing Head comprises a cylindrical stainless steel body housing an infra-red emitter and one or more detectors. Electrical connections are made via pins that pass through a potting compound at the rear of the device. Gas enters the device via two wire meshes, one of which is brazed into the inside of the front face of the enclosure, the second retained by the internal components. The meshes offer a protection against dust ingress of IP5X.

The detector is a pyroelectric type and may be varied to detect a number of different gases. The single detector versions have six or seven pins, the twin-detector builds have eight. If required, all versions of the IR1xxxxxx apart from the models excluded in the Special Condition for Safe Use may be used in intrinsically safe circuits as a galvanically isolating device with infallible separations between the lamp and detector circuits up to 10 V. The maximum input power is 2.5 W.

Variation 1 - This variation permitted the following changes:

- i. The introduction of an 8-pin twin-gas version, incorporating an additional receiver and consequential changes to the PCB layout
- ii. The modification to the special condition for safe use relating to the thermal resistance of the enclosure.
- iii. An increase in the maximum power from 1.0 W to 2.5 W
- iv. The ambient temperature range became -20°C to +55°C (formerly -20°C to +44°C)
- v. The Applicant's name was changed from 'Marconi Applied Technologies' to 'e2v Technologies Ltd'

Variation 2 - This variation permitted the following changes:

- i. The introduction of an alternative method of retaining the wire mesh.
- ii. The introduction of an alternative re-routed PCB to take TO5 or TO39 Dual Package Detectors.
- iii. The introduction of optional thermistor or temperature sensor components.

Variation 3 - This variation permitted the following changes:

- i. Following appropriate re-assessment to demonstrate compliance with the requirements of the EN 60079 series of standards, the documents originally listed in section 9, EN 50014:1997 (amendments A1 to A2), and EN 50018:2000, were replaced by those currently listed, the markings in section 12 were updated accordingly. This re-assessment also endorsed the modifications listed below:
 - The removal of option to fit TO-5 in single and dual channel detectors for carbon dioxide
 - The removal of option to fit "6-Pin, one TO-5 or TO-39 detector" minisensor PCB
 - The removal of surface mount PCB option
 - The option to utilise two alternative 7-Pin PCB track layouts
 - The inclusion of a hand painted conformal coating
- ii. The recognition of minor drawing modifications; these changes are administrative and do not affect the aspects of the product that are relevant to explosion safety.
- iii. The component description and special conditions for safe use were amended.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9401 Issue1

Page 2 of 5

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com



SCHEDULE

EC TYPE-EXAMINATION CERTIFICATE

Sira 99ATEX1121U
Issue 11

Variation 4 - This variation permitted the following changes:

- i. The artwork drawings were changed to omit the reference to the supplier of the FR4 board material and specify another (non-certification) drawing.
- ii. An alternative lamp with a filament support was introduced to improve mechanical robustness.
- iii. The inclusion of mesh support and glass perform items to the main assembly.
- iv. An alternative PCB was added to the IR1xxxxxxx-series; this places the sensor closer to the incandescent lamp for improved response.

Variation 5 - This variation introduced the following changes:

- i. The label drawing N25541R was withdrawn and replaced with drawing N30088A, revision 3 which includes a new product identity for the end user and an optional bar code.
- ii. The product title was changed from IR1xxx to IR1xxxxxxx, the previous references in the description and variations being modified accordingly.

Variation 6 - This variation introduced the following changes:

- i. The introduction of a solder resist (mask) layer was approved.
- ii. The introduction of alternative sourced Pyroelectric detectors was endorsed.
- iii. The correction of minor typographical errors on drawings was accepted.

Variation 7 - This variation introduced the following change:

- i. The Applicant's name and address was changed from e2v Technologies (UK) Limited, 106 Waterhouse Lane, Chelmsford, Essex CM1 2QU, UK to SGX Sensortech (IS) Ltd 2 Hanbury Road, Widford Industrial Estate, Chelmsford, Essex CM1 3AE.

Variation 8 - This variation introduced the following change:

- i. The introduction of the IR1nGJS Series which is rated at 1.5 W and operates in an ambient temperature range of -40°C to +75°C.
- ii. The addition of Ci and Li values and the clarification of the excluded models in the Special Condition for Safe Use dealing with the intrinsically safe applications.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	7 February 2000	R51A4986A	The release of the prime certificate.
1	13 March 2000	R51A4986B	The prime certificate was re-issued to permit report number R51A4986B to replace number R51A4986A.
2	11 July 2002	R52A7947A	The prime certificate was re-issued to permit the removal of the Group I coding.
3	12 May 2004	R52V9860A	The prime certificate was re-issued to permit the product to be re-branded in the name of e2v Technologies Ltd.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9401 Issue1

Page 3 of 5

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com



SCHEDULE

EC TYPE-EXAMINATION CERTIFICATE

Sira 99ATEX1121U
Issue 11

Issue	Date	Report no.	Comment
4	12 November 2004	R52A10469A	The introduction of Variation 1.
5	3 May 2007	R51A16599A	The introduction of Variation 2.
6	18 June 2008	R51A16683D	This Issue covers the following changes: <ul style="list-style-type: none"> All previously issued certification was rationalised into a single certificate, Issue 6, Issues 0 to 5 referenced above are only intended to reflect the history of the previous certification and have not been issued as documents in this format. The introduction of Variation 3.
7	23 February 2009	R52L18828A	The introduction of Variation 4.
8	28 January 2011	R24261A/00	The introduction of Variation 5.
9	18 April 2012	R25570A/00	The introduction of Variation 6.
10	13 November 2012	R29090A/00	The introduction of Variation 7.
11	27 September 2013	R30229A/00	The introduction of Variation 8.

15 SPECIAL CONDITIONS FOR SAFE USE

- 15.1 The IR1xxxxxx-Series gas sensing head shall only be used in an ambient temperature of:
IR1nGJS Series - -40°C to +75°C All other Series - -20°C to +55°C
- 15.2 The IR1nGJS Series shall not be used with the following active detectors:
- H545579A (carbon dioxide)
 - H545580A (methane)
 - H545581A (reference)
 - H548533A (hydrocarbon)
 - H549098A (acetylene)
 - H773980-series (various TO18 detectors)
- 15.3 The thermal resistance of the IR1xxx-Series Gas Sensing Head does not exceed 25 K/W. This shall be taken into account when considering its surface temperature and the temperature classification of the equipment into which it is to be incorporated. Tests indicated that an internal ignition raises the temperature of the mesh by a further 4.2 K (including a 1.2 safety factor).
- 15.4 The IR1xxxxxx-Series Gas Sensing Head shall be protected from impact in service. The Sensing Head shall be mounted in a protective enclosure such that an impact of 7 J in accordance with IEC 60079-0:2007 clause 26.4.2 from any direction shall not cause the impact head to make contact with the Sensing Head.
- 15.5 The IR1xxxxxx is dust-proof (IP5X) but offers no protection against the ingress of water. Where protection in excess of IP50 is required, then the apparatus into which the IR1xxxxxx is installed shall provide the necessary ingress protection (for example by fitting an external semi-permeable membrane).
- 15.6 When used as an intrinsically safe galvanically-isolating device, the IR1xxxxxx has the following safety description:

Lamp circuit	Detector circuit	Lamp + detector circuits
U _i = 7.2 V C _i = 0 L _i = 0	U _i = 10 V C _i = 0 L _i = 0	P _i = 2.5 W

Note: the following types shall not be used as an intrinsically safe, galvanically-isolating devices IR1-xEx, IR1-xFx, IR1-xGx, IR1-xHx, IR1-xTx and IR1nGJS.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9401 Issue1

Page 4 of 5

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com



SCHEDULE

EC TYPE-EXAMINATION CERTIFICATE

Sira 99ATEX1121U
Issue 11

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

17 CONDITIONS OF CERTIFICATION

17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.

17.2 Holders of EC type-examination certificates are required to comply with the production control requirements defined in Article 8 of directive 94/9/EC.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9401 Issue1

Page 5 of 5

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900

Fax: +44 (0) 1244 681330

Email: info@siracertification.com

Web: www.siracertification.com

Certificate Annexe

Certificate Number: Sira 99ATEX1121U
 Component: IR1xxxxxxx-Series Gas Sensing Head
 Applicant: SGX Sensortech (IS) Ltd



Issue 0 and Issue 1

Drawing	Sheet	Rev	Date	Description
DAS546577BA	1 of 1	2	19 Jan 00	IR1xxx Series Certification Drawing
N25541R	1 of 1	2	19 Jan 00	Label

Issue 2

Drawing	Sheet	Rev	Date	Description
DAS546577BA	1 of 1	3	08 Jul 02	IR1xxx Series Certification Drawing
N25541R	1 of 1	4	10 Dec 01	Label

Issue 3

Drawing	Sheet	Rev	Date	Description
DAS546577BA	1 of 1	4	21 Mar 03	IR1xxx Series Certification Drawing
N25541R	1 of 1	5	28 Mar 03	Label

Issue 4

Drawing	Sheet	Rev	Date	Description
DAS546577BA	1 to 2	5	07 Jul 03	IR1xxx general assembly
N25541R	1 to 2	8	05 Oct 04	Label

Issue 5

Drawing	Sheet	Rev	Date (Sira stamp)	Description
DAS546577BA	1 of 3	8	27 Apr 07	IR1 Series Gas Sensor General Assembly
DAS546577BA	2 of 3	8	27 Apr 07	IR1 Series Gas Sensor General Assembly
DAS546577BA	3 of 3	8	27 Apr 07	IR1 Series Gas Sensor General Assembly

Issue 6

Drawing	Sheet	Rev	Date	Description
N25541R	1 of 1	10	11 Jun 08	Label
DAS546577BA	1 to 4	9	06 Jun 08	IR1 Series Gas Sensor General Assembly

Issue 7

Drawing	Sheet	Rev	Date (Sira stamp)	Description
DAS546577BA	1 to 4	10	23 Feb 09	IR1 Series Gas Sensor General Assy
H766212A	1 of 1	1	23 Feb 09	T-1 Incandescent Lamp with Filament Support

Issue 8

Drawing	Sheets	Rev	Date (Sira stamp)	Description
N30088A	2 of 2	3	26 Jan 11	Label

Note – Drawing N25541R withdrawn at Variation 5.

Issue 9

Drawing	Sheets	Rev	Date (Sira stamp)	Description
das 546577BA	1 to 4	11	17 Apr 12	IR1 series Gas sensor

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9401 Issue 1

Page 1 of 2

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

Certificate Annexe

Certificate Number: Sira 99ATEX1121U
 Component: IR1xxxxxxx-Series Gas Sensing Head
 Applicant: SGX Sensortech (IS) Ltd



Issue 10

Drawing	Sheets	Rev	Date (Sira stamp)	Description
LBL - 0008	1 to 2	2	13 Nov 12	IR1 Label

Issue 11

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
LBL-0100	1 to 2	1	30 Jul 13	IR1nGJS ATEX & IEC Certified Label
PAD-0118	1 to 4	1	30 Jul 13	IR1 Series Gas sensor General Assembly

Note - Drawing PAD-0118 replaces drawing DAS546577BA.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9401 Issue 1

Page 2 of 2

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

Headquarter Switzerland:
Angst+Pfister Sensors and Power AG

Thurgauerstrasse 66
CH-8050 Zurich
Phone +41 44 877 35 00
sensorsandpower@angst-pfister.com

Office Germany:
Angst+Pfister Sensors and Power
Deutschland GmbH
Edisonstraße 16
D-85716 Unterschleißheim
Phone +49 89 374 288 87 0
sensorsandpower.de@angst-pfister.com



We are here for you. Addresses and Contacts.

Sales Germany & Austria

Geometrical sensors
Other products

Kurt Stritzelberger
Phone +49 89 374 288 87 22
kurt.stritzelberger@angst-pfister.com

Pressure sensors
Other products

Gerhard Vetter
Phone +49 89 374 288 87 26
gerhard.vetter@angst-pfister.com

Gas sensors and modules

Peter Felder
Phone +41 44 877 35 05
peter.felder@angst-pfister.com

Sales Switzerland & Liechtenstein

Postcode 3000 – 9999

Basil Frei
Phone +41 44 877 35 18
basil.frei@angst-pfister.com

Postcode 1000 – 2999

Christian Mohrenstecher
Phone +41 76 444 57 93
christian.mohrenstecher@angst-pfister.com

Sales International Key Accounts

Peter Felder
Phone +41 44 877 35 05
peter.felder@angst-pfister.com

Sales Other Countries / Product Management

Pressure Sensors
Load Cells

Philipp Kistler
Phone +41 44 877 35 03
philipp.kistler@angst-pfister.com

Gas sensors
Gas sensor modules

Dr. Thomas Clausen
Phone +49 89 374 288 87 24
thomas.clausen@angst-pfister.com

Flow / Level / Medical products

Dr. Adriano Pittarelli
Phone +49 89 374 288 87 67
adriano.pittarelli@angst-pfister.com

Power supplies

Sebastiano Leggio
Phone +41 44 877 35 06
sebastiano.leggio@angst-pfister.com

Linear position sensors
Angle sensors

Eric Letsch
Phone +41 44 877 35 14
eric.letsch@angst-pfister.com

Accelerometers
Sensor elements

Christoph Kleye
Phone +49 89 374 288 87 61
christoph.kleye@angst-pfister.com

Drive technology
CH Postcode 5000 – 9999 / DE

Roman Homa
Phone +41 76 444 00 86
roman.homa@angst-pfister.com

Drive technology
CH Postcode 1000 – 4999 / AT / IT / FR

Christian Mohrenstecher
Phone +41 76 444 57 93
christian.mohrenstecher@angst-pfister.com

Harald Thomas
Phone +49 89 374 288 87 23
harald.thomas@angst-pfister.com